



**NOTES:**

1. ALL UNDERGROUND DETENTION STORAGE PIPE ARE TO BE N-12 TYPE HDPE.
2. THE CONTRACTOR SHALL ENSURE THAT THE INSTALLATION AND BEDDING MATERIALS ARE IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATION.
3. ALL CURB INLETS, GRATE INLETS ARE TO BE VDOT TYPE STRUCTURES AS SHOWN ON THE SITE PLAN AND PROFILES.
4. THE CONTRACTOR SHALL CONTACT MISS UTILITY PRIOR TO ANY TRENCHING OPERATIONS AT 1-800-257-7777!!!!

